

ITS Intertek Testing Services

REPORT OF A

STANDARD FLAME SPREAD TEST PROGRAM

CONDUCTED ON

CROWN MOULDINGS

CLIENT

THE SYNKOLOID COMPANY OF CANADA
11105 BRIDGE STREET
SURREY, B.C.
V3V 3V2

REPORT PREPARED BY

INTERTEK TESTING SERVICES NA LTD.
WARNOCK HERSEY
211 SCHOOLHOUSE STREET
COQUITLAM, B.C.
V3K 4X9


REPORT NUMBER: 493-4818

DATE: FEBRUARY 1999

All services undertaken subject to the following general policy: Reports are submitted for exclusive use of clients to whom they are addressed. Their significance is subject to adequacy and representative character of the sample and to the comprehensiveness of the tests, examinations or surveys made. No quotations from reports or use of WH's name is permitted except as expressly authorized by WH in writing.



Warnock Hersey



Intertek Testing Services NA Ltd.

211 Schoolhouse Street, Coquitlam, BC V3K 4X9 Canada
Telephone 604-520-3321 Fax 604-524-9186 Home Page www.worldlab.com


CONCLUSIONS

The sample of paper covered EPS crown mouldings submitted by The Synkoloid Company of Canada exhibited the following flame spread characteristics, when tested in accordance with CAN/ULC S102-M88 *Standard Method of Test For Surface Burning Characteristics of Building Materials and Assemblies*. These results will also be valid for similar Synkoloid mouldings of similar dimensions.


Material	Flame Spread Classification	Smoke Developed Classification
Paper Covered EPS Crown Mouldings	35	20

INTERTEK TESTING SERVICES NA LTD. WARNOCK HERSEY

Tested and
Reported by:


Paul Saunier
Technologist
Fire Testing Laboratory

Reviewed by:


Michael van Geyn, A.Sc.T.
Manager
Fire Testing Laboratory

PS/gr